



558 West 6th St. Ste. 200

Erie, PA 16507

Toll Free: 844-315-0857

Office: 814-315-0278

Website: <https://rhenergytrans.com>

ABOUT RH ENERGYTRANS LLC

RH energytrans, LLC provides natural gas transportation services to local distribution companies or commercial/industrial customers in Northwestern Pennsylvania and Northeastern Ohio.

More information on RH energytrans, LLC can be found at:
<https://rhenergytrans.com>

WHAT ARE THE SIGNS OF A NATURAL GAS PIPELINE LEAK?

- Blowing or hissing sound
- Dust blowing from a hole in the ground
- Continuous bubbling in wet or flooded areas
- Gaseous or hydrocarbon odor
- Dead or discolored vegetation in a green area
- Flames, if a leak has ignited

WHAT SHOULD I DO IF I SUSPECT A PIPELINE LEAK?

Your personal safety should be your first concern:

- Evacuate the area and prevent anyone from entering
- Abandon any equipment being used near the area
- Avoid any open flames
- Avoid introducing any sources of ignition to the area (such as cell phones, pagers, 2-way radios)
- Do not start/turn off motor vehicles/electrical equipment
- Call 911 or contact local fire or law enforcement
- Notify the pipeline company
- Do not attempt to extinguish a natural gas fire
- Do not attempt to operate any pipeline valves

PIPELINE SAFETY

System failures do not occur frequently along the nation's network of interstate natural gas pipeline facilities. Many of the incidents that do occur are caused by damage from others digging near

the pipeline. We watch for unauthorized digging, but we request your help to notify us.

ALWAYS CALL 811 BEFORE YOU DIG!

PIPELINE LOCATION AND MARKERS

Pipeline markers are used to indicate the approximate location of a natural gas pipeline and to provide contact information. Markers should never be removed or relocated by anyone other than a pipeline operator.

You can also find out where other companies' pipelines are in your area by going to the National Pipeline Mapping System website at www.npms.phmsa.dot.gov.



EMERGENCY CONTACT:

1-800-805-1556

PRODUCTS/DOT GUIDEBOOK ID#/GUIDE#:

Natural Gas 1971 115

OHIO

COUNTIES OF OPERATION:

Ashtabula

Changes may occur. Contact the operator to discuss their pipeline systems and areas of operation.

cause dizziness or asphyxiation without warning and may be toxic if inhaled at high concentrations. Contact with gas or liquefied gas may cause burns, severe injury and/or frostbite.

PRODUCTS TRANSPORTED

Product: Natural Gas

Leak Type: Gas

Vapors: Lighter than air and will generally rise and dissipate. May gather in a confined space and travel to a source of ignition.

Health Hazards: Will be easily ignited by heat, sparks or flames and will form explosive mixtures with air. Vapors may

EMERGENCY RESPONSE PLANS

An Emergency Response Plan is developed for each pipeline facility to contain, control and mitigate the various types of emergency conditions/situations that could occur at one of our facilities. For more information regarding RH energytrans, LLC emergency response plans and procedures, contact us directly.

